Date Event Began	Time Event Began	Date of Restoration	Time of Restoration	Respondent	Area Affected	NERC Region	Event Type	Demand Loss (MW)	Number of Customers Affected
January									
1/7/2013	10:43 AM	1/7/2013	10:43 AM	Delmarva Power & Light Company	Denton, Maryland	RFC	Physcial Attack; Vandalism	Unknown	Unknown
1/16/2013	2:25 PM	1/16/2013	2:25 PM	Delmarva Power & Light Company	Denton, Maryland	RFC	Physcial Attack; Vandalism	Unknown	Unknown
1/16/2013	4:45 PM	1/16/2013	7:26 PM	Public Service Company of New Mexico	San Juan County, New Mexico	WECC	Suspected Physical Attack	0	0
1/16/2013	7:41 AM	1/17/2013	10:58 AM	MidAmerican Energy Co	Webster County, Iowa	MRO	Physical Attack	N/A	N/A
1/17/2013	6:07 PM	1/20/2013	7:30 PM	American Electric Power (AEP)	Southwest Virginia, Southern West Virginia	RFC	Severe Weather - Winter Storm	Unknown	127,000
1/17/2013	7:02 PM	1/19/2013	6:00 PM	Tennessee Valley Authority	Northeast Tennessee	SERC	Severe Weather - Winter Storm	Unknown	80,000
1/17/2013	8:35 PM	1/17/2013	9:20 PM	North Carolina Eastern M P A	Elizabeth City, North Carolina	SERC	Distribution Interruption	40	12,000
1/20/2013	3:30 AM	1/23/2013	6:15 AM	Detroit Edison Co	Southeastern Michigan	RFC	Severe Weather - Wind Storm	Unknown	146,500
1/28/2013	4:46 PM	1/28/2013	6:00 PM	Tacoma Power (TPWR)	Tacoma Narrows Crossing, Washington	WECC	Physical Attack	Unknown	Unknown
1/31/2013	3:05 AM	1/31/2013	4:48 AM	Dominion Virginia Power	Central and Eastern Virginia	SERC	Severe Weather - Wind Storm	188	119,000
1/31/2013	6:30 AM	1/31/2013	10:00 AM	ISO New England	Connecticut	NPCC	Severe Weather - Wind Storm	75	75,000
February									
2/2/2013	9:15 PM	2/2/2013	10:15 PM	El Paso Electric Co.	El Paso, New Mexico	WECC	Vandalism	N/A	N/A
2/7/2013	8:32 AM	2/7/2013	9:47 AM	Duke Energy Ohio Inc	Cincinnati, Ohio	RFC	Vandalism	Unknown	0
2/8/2013	11:38 AM	2/8/2013	2:17 PM	Potomac Electric Power Company	District of Columbia; Prince George's County Maryland	RFC	Equipment Trip & Failure	140	52,000
2/8/2013	8:00 PM	2/11/2013	8:30 PM	ISO New England/National Grid	Central and eastern Massachusetts; Rhode Island	NPCC	Severe Weather - Winter Storm Nemo	N/A	50,000
2/8/2013	8:55 PM	2/12/2013	4:00 AM	ISO New England/NSTAR	Boston area and Southeast Massachusetts	NPCC	Severe Weather - Winter Storm Nemo	Unknown	50,000
2/9/2013	8:30 AM	2/9/2013	3:00 PM	El Paso Electric Co.	El Paso, New Mexico	WECC	Vandalism; Equipment Fault	Unknown	Unknown
2/10/2013	7:46 PM	2/10/2013	8:15 PM	Puerto Rico Electric Power Authority	Puerto Rico	N/A	Generator Trip; Voltage Reduction	350	Unknown
2/13/2013	9:30 AM	2/13/2013	9:30 AM	Potomac Electric Power Company	Fort Washington, Maryland	RFC	Vandalism	1	1
2/13/2013	5:39 PM	2/15/2013	5:50 PM	Footprint Power Salem Harbor Operations LLC	Eastern Massachusetts	NPCC	Fuel Supply Emergency - Petroleum	1	1
2/15/2013	12:00 AM	2/15/2013	12:01 AM	Potomac Electric Power Company	Tuxedo, Maryland	RFC	Vandalism	N/A	N/A
2/16/2013	7:54 AM	2/16/2013	7:54 AM	Potomac Electric Power Company	Prince George's County Maryland	RFC	Vandalism	1	1
2/19/2013	4:01 PM	2/20/2013	12:55 PM	Pacific Gas & Electric Co.	Stockton, California	WECC	Electrical System Separation (Islanding)	13,850	6,810
2/21/2013	11:00 AM	2/21/2013	11:30 AM	El Paso Electric	Las Cruces, New Mexico	WECC	Vandalism	Unknown	Unknown
2/26/2013	1:00 PM	3/1/2013	10:00 AM	Associated Electric Coop, Inc	Northern Missouri	SERC	Severe Weather - Winter Storm Nemo	Unknown	56,444

Date Event Began	Time Event Began	Date of Restoration	Time of Restoration	Respondent	Area Affected	NERC Region	Event Type	Demand Loss (MW)	Number of Customers Affected
March									
3/3/2013	6:39 AM	3/3/2013	10:29 AM	Pacific Gas & Electric Co	Merced County, California	WECC	Transmission System Interruption	300	58,850
3/3/2013	4:27 PM	3/3/2013	6:20 PM	Potomac Electric Power Company	Tacoma Park, Maryland	RFC	Vandalism	Unknown	Unknown
3/4/2013	9:49 AM	3/4/2013	10:00 PM	Puerto Rico Electric Power Authority	Metropolitan area Puerto Rico	N/A	Equipment Failure; Transmission System Interruption	Unknown	Unknown
3/6/2013	8:22 AM	3/7/2013	10:27 AM	Dominion Virginia Power	Northwest Virginia	SERC	Severe Weather - Winter Storm	400	233,000
3/18/2013	5:21 AM	3/18/2013	5:41 AM	Puerto Rico Electric Power Authority	Systemwide Puerto Rico	N/A	Generator Trip; Load Shed	350	262,937
3/18/2013	5:50 PM	3/18/2013	6:07 PM	Jacksonville Electric Authority (JEA)	Northeast Florida	FRCC	Suspected Physical Attack	0	0
3/18/2013	7:30 PM	3/20/2013	2:30 PM	Southern Company	North/Central Alabama; Georgia	SERC	Severe Weather - Thunderstorms	800	240,000
3/23/2013	7:00 AM	3/23/2013	9:00 AM	ISO New England	Connecticut	NPCC	Vandalism	Unknown	Unknown
3/27/2013	10:25 AM	3/27/2013	12:19 PM	ISO New England	Western Massachusetts	NPCC	Physical Attack; Vandalism	Unknown	Unknown
3/28/2013	1:01 PM	3/28/2013	1:02 PM	Delmarva Power & Light Company	Wilmington, Delaware	RFC	Vandalism	Unknown	Unknown
3/29/2013	10:16 AM	3/29/2013	10:17 AM	Baltimore Gas and Electric	Maryland	RFC	Suspected Physical Attack	Unknown	Unknown
April									
4/1/2013	8:40 AM	4/1/2013	8:41 AM	ISO New England	Connecticut	NPCC	Vandalism - Copper Wire Theft	Unknown	Unknown
4/3/2013	11:05 AM	4/3/2013	2:00 PM	Colorado Springs Utilities	Colorado Springs, Colorado	WECC	Sabotage; Vandalism	0	0
4/9/2013	11:30 AM	4/9/2013	11:31 AM	Delmarva Power & Light Company	Delaware City, Delaware	RFC	Vandalism	N/A	N/A
4/16/2013	1:47 AM	4/18/2013	3:25 PM	Pacific Gas & Electric Co	California	WECC	Loss of Part of a High Voltage Substation, Physical Attack	N/A	0
4/17/2013	3:36 PM	4/17/2013	4:53 PM	Tennessee Valley Authority	Colbert Steam Plant in Cherokee, Alabama	SERC	Suspected Physical Attack	Unknown	Unknown
4/18/2013	3:00 PM	4/21/2013	3:30 AM	Detroit Edison Co	Southeast Michigan, Michigan	RFC	Severe Weather - Storms and Wind	Unknown	99,188
4/21/2013	2:11 AM	4/21/2013	12:30 PM	Tennessee Valley Authority	East Tennessee	SERC	Suspected Physical Attack	N/A	N/A
4/23/2013	11:00 AM	4/23/2013	11:01 AM	Delmarva Power & Light Company	Newark, Delaware	RFC	Vandalism	Unknown	Unknown
4/23/2013	12:49 AM	4/23/2013	4:04 AM	Pacific Gas & Electric Co	South of Humboldt, California	WECC	Electrical System Separation (Islanding)	80	1
4/25/2013	4:00 PM	4/26/2013	10:55 AM	City and County of San Francisco	Sunol, California	WECC	Vandalism	0	0
May									
5/1/2013	9:22 AM	5/1/2013	9:24 AM	Xcel Energy/Public Service Company of Colorado	Northeast Colorado	WECC	Electrical System Separation (Islanding)	123	35,230
5/2/2013	6:52 AM	5/2/2013	10:07 AM	WECC	Unknown	WECC	Electrical System Separation (Islanding)	Unknown	Unknown
5/9/2013	1:21 PM	5/9/2013	4:21 PM	WECC	Alberta, Canada; Washington State	WECC	Electrical System Separation (Islanding)	Unknown	Unknown
5/13/2013	12:52 PM	Ongoing	Ongoing	California Department of Water Resources	Central California	WECC	Fuel Supply Emergency - Hydro	176	Unknown

Date Event Began	Time Event Began	Date of Restoration	Time of Restoration	Respondent	Area Affected	NERC Region	Event Type	Demand Loss (MW)	Number of Customers Affected
5/14/2013	12:01 AM	5/14/2013	1:59 PM	PacifiCorp	Portland, Oregon	WECC	Vandalism/Theft	N/A	N/A
5/14/2013	10:25 AM	5/14/2013	11:42 AM	Northeast Utilities/Public Service of New Hampshire	New Hampshire	NPCC	Vandalism	N/A	N/A
5/15/2013	2:11 PM	5/15/2013	2:12 PM	Delmarva Power & Light Company	Wilmington, Delaware	RFC	Vandalism	Unknown	Unknown
5/17/2013	8:35 AM	5/17/2013	8:36 AM	Delmarva Power & Light Company	Newcastle, Delaware	RFC	Vandalism	Unknown	Unknown
5/20/2013	3:00 PM	5/22/2013	5:00 PM	Oklahoma Gas & Electric Co	Moore, Oklahoma	SPP	Severe Weather - Tornados	Unknown	41,306
5/20/2013	5:22 PM	5/20/2013	9:09 PM	Entergy Transmission - SOC	Gonzales Area Louisiana	SERC	Generator Trip; Load Shed 100+ MW	103	21,800
5/22/2013	10:51 AM	5/22/2013	10:57 AM	Puerto Rico Electric Power Authority	System wide Puerto Rico	N/A	System Wide Voltage Reduction	280	197,287
5/28/2013	1:00 PM	5/28/2013	6:00 PM	ISO New England	Maine	NPCC	Vandalism/Theft	None	None
5/29/2013	12:00 AM	5/29/2013	12:02 AM	Dominion Virginia Power	Henrico County, Virginia	SERC	Physical Attack	Unknown	Unknown
5/29/2013	8:58 PM	5/31/2013	2:53 PM	Niagara Mohawk Power Corp.	Central and Eastern New York	NPCC	Severe Weather - Thunderstorms	Unknown	61,795
5/29/2013	9:52 AM	5/29/2013	9:53 AM	Delmarva Power & Light Company	Wilmington, Delaware	RFC	Vandalism/Theft	N/A	N/A
5/30/2013	10:15 AM	5/30/2013	10:16 AM	New York Power Authority	Saranac, New York	NPCC	Vandalism	N/A	N/A
5/31/2013	1:00 AM	5/31/2013	1:30 AM	Southwest Power Pool, Inc.	Maumelle, Arkansas	SPP	Severe Weather - Lightning	N/A	N/A
5/31/2013	6:00 PM	6/4/2013	10:30 AM	Oklahoma Gas & Electric Co	El Reno, S. Oklahoma City, Oklahoma	SPP	Severe Weather - Tornados	Unknown	127,000
5/31/2013	7:07 PM	6/1/2013	2:15 PM	Coffeyville Municipal Light and Power	Southeast Kansas, Northeast Oklahoma	MRO	Transmission System Interruption	102	6,300
5/31/2013	7:30 PM	6/1/2013	8:00 PM	Ameren Missouri	St. Louis Metro Area Missouri	SERC	Severe Weather - Thunderstorms	Unknown	100,000
June									
6/3/2013	12:50 PM	6/3/2013	1:36 PM	WECC RC Vancouver	Alberta, Canada	WECC	Electrical System Separation (Islanding)	Unknown	Unknown
6/13/2013	8:47 PM	6/14/2013	10:47 PM	Southern Company	Southern Company Territory	SERC	Severe Weather - Thunderstorms	550	165,798
6/13/2013	3:30 PM	6/13/2013	4:00 PM	Potomac Electric Power Company	District of Columbia; Maryland	RFC	Loss of 300+ MW Load; Severe Weather -	700	40,000
6/13/2013	4:08 PM	6/14/2013	5:16 PM	Dominion Virginia Power	Richmond Metro area, Virginia	SERC	Severe Weather - Thunderstorms	900	283,000
6/13/2013	1:17 PM	6/14/2013	5:35 PM	Duke Energy Carolinas	Western Piedmont North Carolina	SERC	Severe Weather - Thunderstorms	1,000	175,000
6/13/2013	5:45 PM	6/14/2013	6:30 PM	Duke Energy Progress	Central and Eastern North Carolina	SERC	Severe Weather - Thunderstorms	Unknown	53,000
6/13/2013	3:20 PM	6/14/2013	9:10 PM	American Electric Power	Ohio; Virginia; West Virginia	RFC;	Severe Weather - Thunderstorms	Unknown	90,247
6/17/2013	4:17 PM	6/17/2013	6:49 PM	Tampa Electric Co	Hillsborough County Florida	FRCC	Load Shed of 100+ MW Under Emergency Operational Policy	180	37
6/18/2013	3:51 PM	6/18/2013	4:23 PM	Western Area Power Administration	Wyoming	WECC	Electrical System Separation (Islanding)	6	Unknown
6/19/2013	7:57 PM	6/19/2013	8:09 PM	Western Electricity Coordinating Council	Alberta, Canada	WECC	Electrical System Separation (Islanding)	Unknown	Unknown
6/20/2013	6:00 PM	6/21/2013	10:00 AM	Potomac Electric Power Co	Richie Station (No. 123), Maryland	RFC	Physcial Attack; Vandalism	Unknown	Unknown
6/21/2013	8:31 AM	Ongoing	Ongoing	ITC Transmission	Michigan, Iowa	MRO	Suspected Cyber Attack	Unknown	Unknown

Date Event Began	Time Event Began	Date of Restoration	Time of Restoration	Respondent	Area Affected	NERC Region	Event Type	Demand Loss (MW)	Number of Customers Affected
6/21/2013	7:40 AM	6/21/2013	12:14 PM	Valley Electric Assn, Inc	Pahrump Nevada	WECC	Physical Attack; Vandalism & Sabotage	Unknown	1,100
6/21/2013	3:00 AM	6/26/2013	12:00 PM	Xcel Energy	Minnesota	MRO	Severe Weather - Hailstorm	Unknown	193,000
6/21/2013	11:14 PM	6/21/2013	11:15 PM	Delmarva Power & Light Company	New Castle Delaware	RFC	Physical Attack; Vandalism	Unknown	Unknown
6/21/2013	5:39 PM	6/24/2013	6:00 AM	Xcel Energy	Minneapolis/St. Paul area Minnesota	MRO	Severe Weather - Hailstorm	Unknown	400,000
6/22/2013	4:12 PM	6/22/2013	5:45 PM	NorthWestern Energy LLC - (MT)	Eastern Montana	WECC	Suspected Physical Attack	Unknown	Unknown
6/22/2013	4:59 AM	6/22/2013	9:28 PM	PacifiCorp	Medford Oregon	WECC	Physical Attack; Vandalism	N/A	N/A
6/23/2013	9:20 PM	6/24/2013	1:35 AM	Pacific Gas & Electric Co	Central Coast California	WECC	Severe Weather - Fog	Unknown	148,000
6/24/2013	7:30 PM	6/25/2013	5:46 PM	Exelon Corporation/ComEd	Illinois	RFC	Severe Weather - Thunderstorms	Unknown	283,451
6/24/2013	7:30 PM	6/26/2013	5:00 PM	Northern Indiana Public Service Company	Indiana	RFC	Severe Weather - Thunderstorms	Unknown	86,615
6/27/2013	5:00 PM	6/28/2013	12:00 AM	Detroit Edison Co	South Eastern Michigan	RFC	Severe Weather - Thunderstorms	Unknown	138,000
6/27/2013	1:10 AM	6/27/2013	2:45 AM	Potomac Electric Power Company	Richie Substation,Seat Pleasant, Maryland	l RFC	Physical Attack; Vandalism	Unknown	Unknown
6/28/2013	6:02 PM	6/28/2013	8:46 PM	Southern California Edison Co	Los Angeles and Orange Counties, California	WECC	Equipment Failure	240	65,255
6/28/2013	1:00 PM	6/28/2013	1:01 PM	ISO New England	Vermont	NPCC	Physical Attack; Vandalism	Unknown	Unknown
6/28/2013	5:14 PM	6/28/2013	5:15 PM	Delmarva Power & Light Company	New Castle Delaware	RFC	Physical Attack; Vandalism	Unknown	Unknown

 $^{^{1}} Source: Submissions \ of \ all \ Electric \ Emergency \ Incident \ and \ Disturbance \ Reports \ (OE-417), \ http://www.oe.netl.doe.gov/oe417.aspx$